



Rentals • Sales • Service
24/7 • (800) 227-1966
www.nationwideboiler.com

400 HP FIRETUBE BOILER

Maximum BTU/hr Input (ie: Rated Input @ High Fire / 100% Input Rating)	$400 \times 42,000 = 16,800,000$ BTU
Cubic Feet of Natural Gas Required	$16,800,000 \div 1,000 = 16,800$ Cu Ft
Cubic Feet of Vaporized Propane Required	$16,800,000 \div 2,500 = 6,720$ Cu Ft
Gallons of Liquid Propane Required	$16,800,000 \div 91,600 = 183.4$ Gallons
Gallons of #2 Diesel Oil Required	$16,800,000 \div 140,000 = 120$ Gallons
Minimum BTU/hr Input at a 4:1 Turndown Ratio (Low Fire)	$16,800,000 \div 4 = 4,200,000$ BTU
Cubic Feet of Natural Gas Required	$4,200,000 \div 1,000 = 4,200$ Cu Ft
Cubic Feet of Vaporized Propane Required	$4,200,000 \div 2,500 = 1,680$ Cu Ft
Gallons of Liquid Propane Required	$4,200,000 \div 91,600 = 45.85$ Gallons
Gallons of #2 Diesel Oil Required	$4,200,000 \div 140,000 = 30$ Gallons
Maximum Steam Production in lbs/hr (High Fire)	$400 \times 34.5 = 13,800$ lbs/hr
Maximum Water Evaporation Rate	$400 \times .069 = 27.6$ GPM
Minimum Feedwater Pump Flow (on / off pump strategy)	$27.6 \times 2 = 55.2$ GPM
Minimum Feedwater Pump Flow (modulating pump strategy)	$27.6 \times 1.5 = 41.4$ GPM
Minimum Feedwater Tank Storage Requirement	276 Gallons
Steam Temperature at <u>135 psi</u> Saturated	357 °F
BTU/hr Output, Based on 80% Efficiency at High Fire	$16,800,000 \times .80 = 13,440,000$ BTU
BTU/hr Output, Based on 80% Efficiency at Low Fire	$4,200,000 \times .80 = 3,360,000$ BTU
Square Feet Heating Surface (sq. ft. HS) at 5 sq. ft. per HP	$400 \times 5 = 2,000$ Sq Ft
Minimum Steam Safety Relief Valve Capacity at Boiler Design	$13,800 \times 1.10 = 15,180$ lbs/hr
Minimum Water Softener Flow Capacity at High Fire (always based upon 100% input)	$27.6 \times 2 = 55.2$ GPM

HQ - Fremont, CA (510) 490-7100 - Visalia, CA (559) 623-9318
Washougal, WA (360) 335-1443 / Alvin, TX (800) 227-1966
True Nationwide Coverage & Beyond. Representatives Located Worldwide.